

**AN ORDINANCE AMENDING AND SUPPLEMENTING SECTION 25 OF CHAPTER 330
"RESTORATION; TEMPORARY AND PERMANENT", OF THE REVISED GENERAL
ORDINANCES OF THE BOROUGH OF SPRING LAKE, NEW JERSEY**

WHEREAS, Chapter 330, "Streets and Sidewalks" governs any excavation, removal, replacement, repair, construction, or other disturbance of any portion of the public improvements within a public street or drainage right-of-way as required within the Borough; and

WHEREAS, Section 330-25 is entitled "Restoration; temporary and permanent" and the Mayor and Council having determined that said section be amended and that it is in the best interests of the health, safety and welfare of the residents of the Borough to do so;

NOW, THEREFORE, BE IT HEREBY ORDAINED, by the Borough Council of the Borough of Spring Lake in the County of Monmouth and State of New Jersey that Section 330-25 to Chapter 330 is amended and supplemented with deletions reflected in ~~strikethrough~~ and additions reflected in **bold underline** as follows:

§ 330-25. Restoration; temporary and permanent.

Temporary restoration of the street opening is to be made immediately after the trench has been backfilled and compacted properly. The permanent restoration of the street surface shall be done within a period of three months, weather permitting, from the date that the temporary restoration was installed. The permanent restoration shall, to the extent possible, match or duplicate the original street surface, including any sidewalks, gutters or curbs thereon or contiguous thereto, in type, material, color and texture of the original surface of the streets, sidewalks, gutters or curbs.

A. Once the excavation work area has been properly backfilled and compacted the pavement shall be saw cut and removed a minimum of six inches on each side of the excavation to expose undisturbed subgrade. Excavations less than two feet from the curb line will require removal of existing pavement for the excavation to the curb line. All edges shall be prepared with tack coat.

B. The permittee shall install no less than six inches of bituminous stabilized base course, Stone Mix No. I-2, to the surface of the excavation.

C. All excavations shall be allowed to settle for no less than 90 days and no more than 180 days. During this time period, the permittee shall be responsible for maintaining the surface of the excavation. **If excavations cannot be allowed to settle more than 90 days the contractor shall backfill with soil cement to a minimum of 24 inches below the asphalt pavement.**

D. The permittee shall remove the bituminous stabilized base repair to a depth of 1 1/2 inches below the surface of the existing street by milling. The milling limits should be at least one foot beyond the base repair. The milled area shall be treated with a tack coat and paved with a minimum of 1 1/2 inches of bituminous concrete surface course, Stone Mix No. I-5.

E. In streets constructed of cement concrete with a bituminous concrete overlay pavement shall be replaced with the equivalent concrete and bituminous pavement, thickness to match existing. Replacement of cement concrete with bituminous concrete is not permitted.

F. After an additional period of at least 60 days or as directed by the Borough Engineer, the area shall be repaired using infrared equipment as follows:

- (1) Sweep away any loose soil or standing water from the area to be repaired.**
- (2) Position infrared panel over area to be repaired.**
- (3) Allow infrared to penetrate 5 to 9 minutes depending on depth, season and aggregate.**
- (4) Rake softened in place material removing old joints, seams and rough areas.**
- (5) Rake out a percentage of the ¾" stones from the top 2" of softened base material.**
- (6) Add HMA surface course material as necessary to meet required grade.**
- (7) Compact with vibratory roller as required.**

F.G. All materials and workmanship to be in accordance with the NJDOT Standard Specifications for Road and Bridge Construction.

G. H. If the excavation involves and/or disturbs any lawn area adjacent to the street and/or curb, then this area must be restored to grade and condition existing prior to the excavation. In the event that the adjacent property consisted of a mature, existing lawn, then, and in that event, the disturbed lawn area will be repaired by the replacement of sod turf only and not grass seed.


H.I. At all times the permittee shall not leave, in an unguarded or unprotected area, any machinery or equipment of any type which may have the effect of attracting children and which could be detrimental to their health, safety and welfare.

INTRODUCED: April 22, 2014

ADOPTED: May 13, 2014

APPROVED: 
JENNIFER NAUGHTON, Mayor

Attest:


JANE L. GILLESPIE, Borough Clerk